

Page 1 of 21  
Permit No.: ST-9125  
Issuance Date: December 28, 2005  
Effective Date: February 1, 2006  
Expiration Date: January 31, 2011

STATE WASTE DISCHARGE PERMIT NO. ST-9125

STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY  
CENTRAL REGIONAL OFFICE

In compliance with the provisions of the  
State of Washington Water Pollution Control Law  
Chapter 90.48 Revised Code of Washington, as amended,  
and  
the Federal Water Pollution Control Act  
(The Clean Water Act)  
Title 33 United States Code, Section 1251 et seq.,  
authorizes

**CENTENNIAL TANK CLEANING, INC.**  
**511 E. SOUTH HILL ROAD**  
**SUNNYSIDE, WASHINGTON 98944**

to discharge wastewater in accordance with the special and general conditions which follow.

<u>Facility Address:</u> Same as above	<u>Discharge Location</u> Latitude: 46° 18' 33" N Longitude: 120° 00' 49" W
<u>Publicly Owned Treatment Works Receiving Discharge:</u> Port of Sunnyside Industrial Wastewater Treatment Facility (IWWTF)	
<u>Industry Type:</u> Transportation Equipment Cleaning	<u>SIC Code:</u> 7699 (Services not elsewhere classified)

---

G. Thomas Tebb, L.E.G.  
Section Manager  
Water Quality Program  
Central Region Office  
Washington State Department of Ecology

TABLE OF CONTENTS

	<u>Page</u>
SUMMARY OF PERMIT REPORT SUBMITTALS.....	4
SPECIAL CONDITIONS.....	5
S1.    DISCHARGE LIMITATIONS .....	5
A.    Effluent Limitations .....	5
B.    Schedule of Compliance for Meeting the Pretreatment Standards .....	5
1.    Numerical Limitations .....	6
2.    Pollution Prevention Plan .....	6
S2.    MONITORING REQUIREMENTS .....	7
A.    Wastewater Monitoring.....	7
B.    Sampling and Analytical Procedures .....	8
C.    Flow Measurement.....	8
D.    Laboratory Accreditation .....	9
E.    Request for Reduction of Monitoring .....	9
S3.    REPORTING AND RECORDKEEPING REQUIREMENTS .....	9
A.    Reporting.....	9
B.    Records Retention .....	10
C.    Recording of Results .....	10
D.    Additional Monitoring by the Permittee .....	10
E.    Noncompliance Notification .....	10
F.    Dangerous Waste Discharge Notification.....	11
G.    Spill Notification.....	11
H.    Maintaining a Copy of This Permit.....	11
S4.    OPERATION AND MAINTENANCE (O&M).....	11
A.    O&M Manual .....	11
B.    Bypass Procedures .....	12
S5.    PROHIBITED DISCHARGES .....	14
A.    General Prohibitions .....	14
B.    Specific Prohibitions .....	14
C.    Prohibited Unless Approved .....	15
S6.    DILUTION PROHIBITED .....	15
S7.    SOLID WASTE DISPOSAL .....	15
A.    Solid Waste Handling .....	15
B.    Leachate .....	15
C.    Solid Waste Control Plan .....	16
S8.    SPILL AND SLUG DISCHARGE PREVENTION AND CONTROL PLAN .....	16
GENERAL CONDITIONS .....	18
G1.    SIGNATURE AUTHORIZATION/DELEGATION.....	18

G2.	RIGHT OF ENTRY .....	18
G3.	PERMIT ACTIONS.....	19
G4.	REPORTING A CAUSE FOR MODIFICATION .....	19
G5.	PLAN REVIEW REQUIRED .....	19
G6.	COMPLIANCE WITH OTHER LAWS AND STATUTES .....	20
G7.	DUTY TO REAPPLY .....	20
G8.	PERMIT TRANSFER.....	20
G9.	REDUCED PRODUCTION FOR COMPLIANCE .....	20
G10.	REMOVED SUBSTANCES .....	20
G11.	PAYMENT OF FEES .....	21
G12.	PENALTIES FOR VIOLATING PERMIT CONDITIONS.....	21

### SUMMARY OF PERMIT REPORT SUBMITTALS

Refer to the Special and General Conditions of this permit for additional submittal requirements.

Permit Section	Submittal	Frequency	First Submittal Date
Schedule of Compliance--Permittee must comply with requirements of S1.B1 or S1.B2.			
S1.B1.	Engineering Report	1/permit cycle	March 15, 2006
S1.B1.	Compliance with the Pretreatment Numerical Limitations	1/permit cycle	October 15, 2006
S1.B2.	Compliance with the Pretreatment Pollution Prevention Plan	1/permit cycle	October 15, 2006
All following submittals are required as specified.			
S3.A.	Discharge Monitoring Report	Monthly	March 15, 2006
S4.A.	Operation and Maintenance Manual	1/permit cycle	April 15, 2006
S4.A.	O&M Manual Update or Review Confirmation Letter	As necessary	As necessary
S7.C.	Solid Waste Control Plan	1/permit cycle	April 15, 2006
S7.C.	Solid Waste Control Plan Update	As necessary	As necessary
S8.	Spill and Slug Discharge Prevention and Control Plan	1/permit cycle	April 15, 2006
G1.	Signature Authorization/Delegation	As Needed	As Needed
G7.	Application for permit renewal	1/permit cycle	January 31, 2010

## SPECIAL CONDITIONS

### S1. DISCHARGE LIMITATIONS

#### A. Effluent Limitations

All discharges and activities authorized by this permit shall be consistent with the terms and conditions of this permit. The discharge of any of the following pollutants more frequently than, or at a concentration in excess of, that authorized by this permit shall constitute a violation of the terms and conditions of this permit.

Beginning on **February 1, 2006** and lasting through **January 31, 2011**, the discharge from this facility shall be subject to limitations established by the Industrial Wastewater Treatment Facility (IWWTF) User Contract between Centennial Tank Cleaning, Inc. and the Port of Sunnyside. At the time of issuance of this permit, the contract, dated January 1, 2001, is in effect. The effluent limitations in the contract constitute the enforceable limits of this permit (with the exception of pH, which is not addressed in the User Contract).

The Department anticipates that Centennial Tank Cleaning, Inc. and the Port of Sunnyside may renegotiate the contract during the course of this permit as more information is generated on the variability of the discharge and the Port's treatment capacity. Upon establishment of a new contract, the facility shall submit the contract to the Department for approval. Upon approval, the contract shall be incorporated into the facility's Operating and Maintenance Manual as a replacement Appendix A and the limitations established in the new contract will become the enforceable limits of this permit.

pH Effluent Limitation	
pH (standard units)	Shall not be outside the range of 4.0 to 11.0

#### B. Schedule of Compliance for Meeting the Pretreatment Standards

The Permittee shall achieve compliance with the Federal pretreatment standards. The Permittee shall either: 1) achieve compliance with the numerical limitations for Copper, Mercury and Non-polar Materials contained in the following table, or, 2) submit a Pollution Prevention Plan to the Department for review and approval.

**1. Numerical Limitations**

In the event the Permittee chooses this option, the Permittee shall submit an engineering report to the Department for review and approval by **March 15, 2006**.

Parameter	Daily Maximum
Copper	840 µg/L
Mercury	3.1 µg/L
Non-polar Materials	26 mg/L

The Permittee shall be in compliance with the numerical limitations by **October 15, 2006**.

**2. Pollution Prevention Plan**

In the event the Permittee chooses this option, the Permittee shall complete the planned upgrade of its oil-water separator and submit a Pollution Prevention Plan to the Department for review and approval by **October 15, 2006**. In this option, an engineering report is not required for the oil/water separator upgrade. The Pollution Prevention Plan shall be written in accordance with the requirements specified in 40 CFR 442.15(b) (see Appendix C).

## S2. MONITORING REQUIREMENTS

### A. Wastewater Monitoring

The Permittee shall monitor the wastewater according to the following schedule:

Parameter	Units	Sample Point <sup>a</sup>	Sampling Frequency	Sample Type
Flow	Cubic feet per month	At weir	Continuous <sup>b</sup>	Ultrasonic sensor
Flow	Million gallons (MG)	At weir	Continuous	Ultrasonic sensor
Chemical Oxygen Demand (COD)	mg/L	At weir	1/week	24-hour composite <sup>c</sup>
COD	lbs/month	At weir	1/week	Calculation
Total Suspended Solids (TSS)	mg/L	At weir	1/week	24-hour composite
TSS	lbs/month	At weir	1/week	Calculation
Total Kjeldahl Nitrogen (TKN)	mg/L	At weir	2/month <sup>d</sup>	24-hour composite
TKN	lbs/month	At weir	2/month	Calculation
Total Phosphorus (P)	mg/L	At weir	2/month	24-hour composite
Total P	lbs/month	At weir	2/month	Calculation
Chloride	mg/L	At weir	2/month	24-hour composite
Chloride	lbs/month	At weir	2/month	Calculation
Total Dissolved Solids (TDS)	mg/L	At weir	2/month	24-hour composite
TDS	lbs/month	At weir	2/month	Calculation
Total Fixed Solids	mg/L	At weir	2/month	24-hour composite
Total Fixed Solids	lbs/month	At weir	2/month	Calculation
pH	Standard Units	At weir	1/week	24-hour composite
Non-polar Materials (SGT-HEM)	mg/L	At weir	1/month <sup>e</sup>	24-hour composite
Copper	µg/L	At weir	2/year <sup>f</sup>	24-hour composite
Mercury	µg/L	At weir	1/year <sup>g</sup>	24-hour composite
a-The sample point shall be at the weir downstream of the oil/water separator.				
b-"Continuous" means without interruption throughout the operating and discharging hours of the Permittee's facility, except for infrequent shutdowns for maintenance.				
c-"24-hour composite" means a series of individual samples collected over a 24-hour period into a single container, and analyzed as one sample.				

d-"2/month" means twice per calendar month. Samples shall not be taken during the same calendar week.
e-"1/month" means once every calendar month. Samples shall not be taken during the same calendar week.
f-"2/year" means twice each calendar year. The first sample shall be taken during the January - June period and the second shall be taken in the July - December period. Samples shall be taken at least one calendar month apart.
g-"1/year" means once each calendar year. Samples shall be taken at least one calendar month apart. Analysis shall be in compliance with the requirements of 40 CFR 136. Method detection level (MDL) of analytical method shall be at least one magnitude below the 3.1 µg/L effluent limit.

**B. Sampling and Analytical Procedures**

Samples and measurements taken to meet the requirements of this permit shall be representative of the volume and nature of the monitored parameters, including representative sampling of any unusual discharge or discharge condition, including bypasses, upsets and maintenance-related conditions affecting effluent quality.

Sampling and analytical methods used to meet the water and wastewater monitoring requirements specified in this permit shall conform to the latest revision of the *Guidelines Establishing Test Procedures for the Analysis of Pollutants* contained in 40 CFR Part 136 or to the latest revision of *Standard Methods for the Examination of Water and Wastewater* (APHA), unless otherwise specified in this permit or approved in writing by the Department of Ecology (Department).

**C. Flow Measurement**

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the quantity of monitored flows. The devices shall be installed, calibrated, and maintained to ensure that the accuracy of the measurements are consistent with the accepted industry standard for that type of device. Frequency of calibration shall be in conformance with manufacturer's recommendations and at a minimum frequency of at least one calibration per year. Calibration records shall be maintained for at least three years.



**D. Laboratory Accreditation**

All monitoring data required by the Department shall be prepared by a laboratory registered or accredited under the provisions of, *Accreditation of Environmental Laboratories*, Chapter 173-50 WAC.

**E. Request for Reduction of Monitoring**

The Permittee may request a reduction of the sampling frequency after 12 months of monitoring. The request shall: (1) be in written form, (2) clearly state the parameters for which the reduction in monitoring is being requested, and (3) clearly state the justification for the reduction. Any request for reduction in monitoring shall be granted at the Department of Ecology's (Department) discretion and accomplished through an Administrative Order or permit modification.

**S3. REPORTING AND RECORDKEEPING REQUIREMENTS**

The Permittee shall monitor and report in accordance with the following conditions. The falsification of information submitted to the Department shall constitute a violation of the terms and conditions of this permit.

**A. Reporting**

The first monitoring period begins on **February 1, 2006**. Monitoring results shall be submitted monthly. Monitoring data obtained during the previous month shall be summarized and reported on a form provided, or otherwise approved, by the Department, and be received no later than the 15<sup>th</sup> day of the month following the completed reporting period, unless otherwise specified in this permit. The report(s) shall be sent to:

Permit Data Systems Manager  
Department of Ecology  
Central Regional Office  
15 West Yakima Avenue, Suite 200  
Yakima, Washington 98902

Discharge Monitoring Report forms must be submitted monthly whether or not the facility was discharging. If there was no discharge or the facility was not operating during a given monitoring period, submit the form as required with the words "no discharge" entered in place of the monitoring results.

**B. Records Retention**

The Permittee shall retain records of all monitoring information for a minimum of 3 years. Such information shall include all calibration and maintenance records and all original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit. This period of retention shall be extended during the course of any unresolved litigation regarding the discharge of pollutants by the Permittee or when requested by the Director.

**C. Recording of Results**

For each measurement or sample taken, the Permittee shall record the following information: (1) the date, exact place, method, and time of sampling; (2) the individual who performed the sampling or measurement; (3) the dates the analyses were performed; (4) who performed the analyses; (5) the analytical techniques or methods used; and (6) the results of all analyses.

**D. Additional Monitoring by the Permittee**

If the Permittee monitors any pollutant more frequently than required by this permit using test procedures specified by Special Condition S2. of this permit, then the results of this monitoring shall be included in calculation and reporting of the data submitted in the Permittee's self-monitoring reports.

**E. Noncompliance Notification**

In the event the Permittee is unable to comply with any of the permit terms and conditions due to any cause, the Permittee shall:

1. Immediately take action to stop, contain, and cleanup unauthorized discharges or otherwise stop the violation, and correct the problem;
2. Repeat sampling and analysis of any violation and submit the results to the Department within 30 days after becoming aware of the violation;
3. Immediately notify the Department and the local sewage treatment plant manager of the failure to comply; and

4. Submit a detailed written report to the Department within 30 days (five days for upsets and bypasses), unless requested earlier by the Department. The report should describe the nature of the violation, corrective action taken and/or planned, steps to be taken to prevent a recurrence, results of the resampling, and any other pertinent information.

Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit or the resulting liability for failure to comply.

**F. Dangerous Waste Discharge Notification**

The Permittee shall notify the POTW and the Department in writing of the intent to discharge into the POTW any substance designated as a dangerous waste in accordance with the provisions of WAC 173-303-070. This notification shall be made at least 90 days prior to the date that discharge is proposed to be initiated.

**G. Spill Notification**

The Permittee shall notify the POTW immediately (as soon as discovered) of all discharges that could cause problems to the POTW, such as process spills and unauthorized discharges (including slug discharges).

**H. Maintaining a Copy of This Permit**

A copy of this permit shall be kept at the facility and be made available upon request to Ecology inspectors.

**S4. OPERATION AND MAINTENANCE (O&M)**

The Permittee shall at all times be responsible for the proper O&M of any facilities or systems of control installed to achieve compliance with the terms and conditions of the permit.

**A. O&M Manual**

An O&M Manual shall be prepared by the Permittee in accordance with WAC 173-240-150. The manual shall be submitted to the Department for approval within by **April 15, 2006**. Substantial changes or updates to the O&M Manual shall be submitted to the Department for review and approval whenever they are incorporated into the manual.

The approved Operations and Maintenance Manual shall be kept available at the permitted facility and all operators shall follow the instructions and procedures of this manual.

In addition to the requirements of WAC 173-240-150(1) and (2), the O&M Manual shall include:

1. Emergency procedures for plant shutdown and cleanup in event of wastewater system upset or failure;
2. Wastewater system maintenance procedures that contribute to the generation of process wastewater;
3. Any directions to maintenance staff when cleaning, or maintaining other equipment or performing other tasks which are necessary to protect the operation of the wastewater system (e.g. defining maximum allowable discharge rate for draining a tank, blocking all floor drains before beginning the overhaul of a stationary engine.);
4. O&M of sampling equipment (e. g., autosamplers, flow meters) used to verify compliance with the requirements of this permit;
5. Appendix A--the most current Department-approved User Contract with the Port;
6. Appendix B--the most current Solid Waste Plan; and,
7. Appendix C--the most current Spill and Slug Discharge prevention and Control Plan.

**B. Bypass Procedures**

The Permittee shall immediately notify the Department and the receiving POTW of any spill, overflow, or bypass from any portion of the collection or treatment system.

The bypass of wastes from any portion of the treatment system is prohibited unless one of the following conditions (1, 2, or 3) applies:

1. Unavoidable Bypass—Bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. “Severe property damage” means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass.

If the resulting bypass from any portion of the treatment system results in noncompliance with this permit the Permittee shall notify the Department and the receiving POTW in accordance with Special Condition S3.E “Noncompliance Notification.”

2. Anticipated Bypass That Has The Potential to Violate Permit Limits or Conditions—Bypass is authorized by an administrative order issued by the Department. The Permittee shall notify the Department and the POTW at least 30 days before the planned date of bypass. The notice shall contain a description of the bypass and its cause; the duration of the bypass, including exact dates and times; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass. The Department will consider the following prior to issuing an administrative order:
  - a. If the bypass is necessary to perform construction or maintenance-related activities essential to meet the requirements of the permit.
  - b. If there are feasible alternatives to bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, stopping production, maintenance during normal periods of equipment down time, or transport of untreated wastes to another treatment facility.
  - c. If the bypass is planned and scheduled to minimize adverse effects on the public and the environment.

After consideration of the above and the adverse effects of the proposed bypass and any other relevant factors, the Department will approve or deny the request. The public shall be notified and given an opportunity to comment on bypass incidents of significant duration, to the extent feasible. Approval of a request to bypass will be by administrative order issued by the Department under RCW 90.48.

3. Bypass For Essential Maintenance Without the Potential to Cause Violation of Permit Limits or Conditions -- Bypass is authorized if it is for essential maintenance and does not have the potential to cause violations of limitations or other conditions of the permit, a violation of a pretreatment standard or requirement, or adversely impact public health as determined by the Department prior to the bypass.

## **S5. PROHIBITED DISCHARGES**

### **A. General Prohibitions**

The Permittee shall not introduce into the POTW pollutant(s) which cause Pass Through or Interference.

### **B. Specific Prohibitions**

In addition, the following shall not be introduced into the POTW:

1. Pollutants which create a fire or explosion hazard in the POTW, including, but not limited to, waste streams with a closed cup flashpoint of less than 60°C (140°F) using the test methods specified in 40 CFR 261.21.
2. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW resulting in interference;
3. Any pollutant, including oxygen demanding pollutants (BOD, etc.), released in a discharge at a flow rate and/or pollutant concentration which will cause interference with the POTW;
4. Heat in amounts which will inhibit biological activity in the POTW resulting in interference, but in no case heat in such quantities that the temperature at the POTW treatment plant exceeds 40°C (104°F) unless the approval authority, upon request of the POTW, approves alternative temperature limits;
5. Petroleum oil, non-biodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass through;
6. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems;
7. Any trucked or hauled pollutants, except at discharge points designated by the POTW.
8. Pollutants which will cause corrosive structural damage to the POTW.

**C. Prohibited Unless Approved**

1. Any of the following discharges are prohibited unless approved by the Department under extraordinary circumstances (such as a lack of direct discharge alternatives due to combined sewer service or a need to augment sewage flows due to septic conditions):
  - a. Noncontact cooling water in significant volumes.
  - b. Storm water and other direct inflow sources.
  - c. Wastewaters significantly affecting system hydraulic loading, which do not require treatment or would not be afforded a significant degree of treatment by the system.
2. Unless specifically authorized in this permit, the discharge of dangerous wastes as defined in Chapter 173-303 WAC, is prohibited.

**S6. DILUTION PROHIBITED**

The Permittee shall not dilute the wastewater discharge with stormwater or increase the use of potable water, process water, noncontact cooling water, or, in any way, attempt to dilute an effluent as a partial or complete substitute for adequate treatment to achieve compliance with the limitations contained in this permit.

**S7. SOLID WASTE DISPOSAL**

**A. Solid Waste Handling**

The Permittee shall handle and dispose of all solid waste material in such a manner as to prevent its entry into State ground water, surface water or a POTW.

**B. Leachate**

The Permittee shall not allow leachate from its solid waste material to enter State waters without providing all known, available and reasonable methods of prevention, control and treatment (AKART), nor allow such leachate to cause violations of the State Surface Water Quality Standards, Chapter 173-201A WAC, or the State Ground Water Quality Standards, Chapter 173-200 WAC. The Permittee shall apply for a permit or permit modification as may be required for such discharges to State ground or surface waters.

**C. Solid Waste Control Plan**

The Permittee shall submit a Solid Waste Control Plan to the Department by **April 15, 2006**. This plan shall include all solid wastes with the exception of those solid wastes regulated by Chapter 173-303 WAC (Dangerous Waste Regulations). The plan shall include at a minimum a description, source, generation rate, and disposal methods of these solid wastes. This plan shall not be at variance with any approved local solid waste management plan. The plan shall be incorporated into Appendix B of the O&M Manual. Any proposed revision or modification of the solid waste handling plan must be submitted to the Department. The Permittee shall comply with the plan and any modifications thereof.

**S8. SPILL AND SLUG DISCHARGE PREVENTION AND CONTROL PLAN**

By **April 15, 2006**, the Permittee shall submit to the Department a Spill and Slug Discharge Prevention and Control Plan for the prevention, containment, and control of spills or unplanned releases. The Permittee shall review and update the plan as needed. Changes to the plan shall be sent to the Department. The plan and any supplements shall be incorporated into Appendix C of the O&M Manual and be followed throughout the term of the permit.

The Spill and Slug Discharge Prevention and Control Plan shall include the following:

1. A description of a reporting system to be used to immediately notify facility management, the POTW operator, and appropriate State, Federal, and local authorities of any spills or slug discharges, and provisions to provide a written follow-up report within five days;
2. A description of operator training, equipment, and facilities (including overall facility plan) for preventing, containing, or treating spills or slug discharges;
3. A list of all raw materials, products, chemicals, and hazardous materials used, processed, or stored at the facility; the normal quantity maintained on the premises for each listed material; and a map showing where they are located.
4. A description of discharge practices for batch and continuous processes under normal and non-routine circumstances;
5. A brief description of any unauthorized discharges which occurred during the 36-month period preceding the effective date of this permit and subsequent measures



taken by Permittee to prevent or to reduce the possibility of further unauthorized discharges; and

6. An implementation schedule including additional operator training and procurement and installation of equipment or facilities required to properly implement the plan.

Plans and manuals required by 40 CFR Part 112, contingency plans required by chapter 173-303 WAC, or other plans required by other agencies which meet the intent of this section may be submitted.

The current approved plan shall be maintained on the plant site and be readily available to facility personnel. The Permittee shall submit an update of the Spill and Slug Discharge Prevention and Control Plan, or a certification that it is current with the application for permit renewal.

## **GENERAL CONDITIONS**

### **G1. SIGNATURE AUTHORIZATION/DELEGATION**

All applications, reports, or information submitted to the Department shall be signed as follows:

- A. All permit applications shall be signed by either a principal executive officer or ranking elected official.
- B. All reports required by this permit and other information requested by the Department shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - 1. The authorization is made in writing by the person described above and is submitted to the Department at the time of authorization, and
  - 2. The authorization specifies either a named individual or any individual occupying a named position.
- C. Changes to authorization. If an authorization under paragraph B.2. above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization must be submitted to the Department prior to or together with any reports, information, or applications to be signed by an authorized representative.
- D. Certification. Any person signing a document under this section shall make the following certification:

"I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

### **G2. RIGHT OF ENTRY**

Representatives of the Department shall have the right to enter at all reasonable times in or upon any property, public or private, for the purpose of inspecting and investigating conditions relating to the pollution or the possible pollution of any waters of the State.

Reasonable times shall include normal business hours; hours during which production, treatment, or discharge occurs; or times when the Department suspects a violation requiring immediate inspection. Representatives of the Department shall be allowed to have access to, and copy at reasonable cost, any records required to be kept under terms and conditions of the permit; to inspect any monitoring equipment or method required in the permit; and to sample the discharge, waste treatment processes, or internal waste streams.

### **G3. PERMIT ACTIONS**

This permit shall be subject to modification, suspension, or termination, in whole or in part by the Department for any of the following causes:

- A. Violation of any permit term or condition;
- B. Obtaining a permit by misrepresentation or failure to disclose all relevant facts;
- C. A material change in quantity or type of waste disposal;
- D. A material change in the condition of the waters of the State; or
- E. Nonpayment of fees assessed pursuant to RCW 90.48.465.

The Department may also modify this permit, including the schedule of compliance or other conditions, if it determines good and valid cause exists, including promulgation or revisions of regulations or new information.

### **G4. REPORTING A CAUSE FOR MODIFICATION**

The Permittee shall submit a new application, or a supplement to the previous application, along with required engineering plans and reports, whenever a new or increased discharge or change in the nature of the discharge is anticipated which is not specifically authorized by this permit. This application shall be submitted at least 60 days prior to any proposed changes. Submission of this application does not relieve the Permittee of the duty to comply with the existing permit until it is modified or reissued.

### **G5. PLAN REVIEW REQUIRED**

Prior to constructing or modifying any wastewater control facilities, an engineering report and detailed plans and specifications shall be submitted to the Department for approval in accordance with Chapter 173-240 WAC. Engineering reports, plans, and specifications should be submitted at least 180 days prior to the planned start of construction. Facilities shall be constructed and operated in accordance with the approved plans.

**G6. COMPLIANCE WITH OTHER LAWS AND STATUTES**

Nothing in the permit shall be construed as excusing the Permittee from compliance with any applicable Federal, State, or local statutes, ordinances, or regulations.

**G7. DUTY TO REAPPLY**

The Permittee must apply for permit renewal at least 1 year prior to the specified expiration date of this permit.

**G8. PERMIT TRANSFER**

This permit is automatically transferred to a new owner or operator if:

- A. A written agreement between the old and new owner or operator containing a specific date for transfer of permit responsibility, coverage, and liability is submitted to the Department;
- B. A copy of the permit is provided to the new owner and the receiving POTW is notified and;
- C. The Department does not notify the Permittee of the need to modify the permit.

Unless this permit is automatically transferred according to section A. above, this permit may be transferred only if it is modified to identify the new Permittee and to incorporate such other requirements as determined necessary by the Department.

**G9. REDUCED PRODUCTION FOR COMPLIANCE**

The Permittee shall control production or discharge to the extent necessary to maintain compliance with the terms and conditions of this permit upon reduction of efficiency, loss, or failure of its treatment facility until the treatment capacity is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power for the treatment facility is reduced, lost, or fails.

**G10. REMOVED SUBSTANCES**

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters shall not be resuspended or reintroduced to the effluent stream for discharge.

**G11. PAYMENT OF FEES**

The Permittee shall submit payment of fees associated with this permit as assessed by the Department. The Department may revoke this permit if the permit fees established under Chapter 173-224 WAC are not paid.

**G12. PENALTIES FOR VIOLATING PERMIT CONDITIONS**

Any person who is found guilty of willfully violating the terms and conditions of this permit shall be deemed guilty of a crime, and upon conviction thereof shall be punished by a fine of up to \$10,000 and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs may be deemed a separate and additional violation.

Any person who violates the terms and conditions of a waste discharge permit shall incur, in addition to any other penalty as provided by law, a civil penalty in the amount of up to \$10,000 for every such violation. Each and every such violation shall be a separate and distinct offense, and in case of a continuing violation, every day's continuance shall be and be deemed to be a separate and distinct violation.